



GUIDANCE NOTES
GD46-2023

CHINA CLASSIFICATION SOCIETY

GUIDELINES FOR ONBOARD CARBON CAPTURE SYSTEMS

2023

Effective from 1 January 2024

Beijing

CONTENTS

Chapter 1	General	1
1.1	General provisions	1
1.2	Functional and objective requirements	1
1.3	Definitions and abbreviations	2
1.4	Class notations	3
1.5	Plans and information	3
1.6	Risk assessment	4
1.7	Operation and maintenance manual	5
Chapter 2	Design and Arrangement	6
2.1	General provisions	6
2.2	Ship arrangement	6
2.3	Strength and stability	7
2.4	Compatibility with combustion unit	7
2.5	Exhaust gas back pressure	8
2.6	Exhaust bypass or equivalent measures	8
2.8	Electrical installations	9
2.9	Explosion protection	9
Chapter 3	CO ₂ Absorption and Desorption	10
3.1	General provisions	10
3.2	Absorber unit	10
3.3	Absorbent circulation system	11
3.4	Desorber unit	12
3.5	Cooling water system	12
3.6	Piping system	13
Chapter 4	Decarbonization Agent Supply System	14
4.1	General provisions	14
4.2	Storage of decarbonization agent	14
4.3	Filling of decarbonization agent	16
4.4	Filter	16
4.5	Decarbonization agent overflow tank	16
4.6	Protection measures	17
Chapter 5	CO ₂ Compression and Liquefaction	18
5.1	General provisions	18
5.2	Compression and liquefaction	18
5.3	Piping system	18
5.4	Ventilation	19
Chapter 6	CO ₂ Storage and Unloading	20
6.1	General provisions	20
6.2	Containment system of CO ₂ storage tanks	20
6.3	Ventilation system	20
6.4	CO ₂ unloading	21
6.5	Monitoring and alarm of CO ₂ storage tanks	21

Chapter 7	Control, Monitoring , Alarm and Safety System	23
7.1	General provisions	23
7.2	Control, monitoring and alarm system	23
7.3	Safety system	23
7.4	Gas detection system	24
Chapter 8	Surveys	28
8.1	General provisions	28
8.2	Drawings examination	28
8.3	Product surveys	28
8.4	Surveys during construction	28
8.5	Surveys after construction	29
Chapter 9	Ready Technology Requirements for OCCS	31
9.1	General provisions	31
9.2	Requirements of ready	31
9.3	Plans and information	31
9.4	Surveys	32

Chapter 1 General

1.1 General provisions

1.1.1 This Guidelines is applicable to Onboard Carbon Capture Systems (OCCS) installed to reduce CO₂ emissions onboard the ships.

1.1.2 This Guidelines provides the classification requirements for the design, onboard installation and arrangement, control and monitoring, survey and testing, etc. of OCCS. The conventional ship systems and/or equipment shared with OCCS is to comply with relevant requirements of international conventions, codes, and China Classification Society (CCS) rules.

1.1.3 This Guidelines applies to OCCS using organic amine as decarbonization agent. Special consideration is to be given for the OCCS using other types of decarbonization agent or methods.

1.1.4 In addition to the provisions of this Guidelines, OCCS is also to comply with the relevant requirements of the Rules for Classification of Sea-going Steel Ships (the CCS Rules) or other applicable rules and the requirements of the competent authorities.

1.2 Functional and objective requirements

1.2.1 This guidelines intends to provide standards for the design, installation and arrangement on board, survey and testing, and operational safety of OCCS to minimize the harm that the installation and operation of OCCS may cause to ships, crew members and the environment.

1.2.2 To achieve the aforementioned objectives, the design, onboard installation and arrangement of OCCS are to meet the following functional requirements:

- (1) Applicable to the environmental and working conditions of operations on board the ships;
- (2) Effectively handling CO₂ in the exhaust gas of the combustion unit connected to it;
- (3) Minimizing the impact of OCCS installation and operation on the combustion unit as much as possible, ensuring that the combustion unit can operate continuously and that operating parameters, power output, etc. are always maintained within the design range;
- (4) The mechanical properties, chemical composition, manufacturing, and testing of the materials used are to meet the relevant requirements of the Rules for Materials and Welding (the CCS Material Rules), and anti-corrosion measures is to be considered (if applicable);
- (5) Preventing the accidental accumulation or diffusion of flammable, explosive, and toxic gases;
- (6) Preventing the leakage and diffusion of chemicals such as absorbents;
- (7) Preventing damage to crew members or other system equipment caused by high/low temperature, high pressure and operating equipment;
- (8) Taking appropriate fire detection, prevention and extinguishing measures in response to potential fire risks;
- (9) Considering the impact of the installation and arrangement of OCCS on hull structures, stability, load lines, bridge room visibility;
- (10) Taking appropriate control, monitoring, and safety protection measures to ensure the safe and reliable operation of OCCS;
- (11) Facilitating survey, maintenance and renewal of internal parts and components for relevant systems and equipment.

1.3 Definitions and abbreviations

1.3.1 Definitions applicable to this Guidelines are as follows:

(1) Onboard Carbon Capture System means a complete system that uses decarbonization agents to capture CO₂ from the exhaust gas of combustion units on board the ships, generally consisting of absorber unit, desorber unit, CO₂ compression and liquefaction unit, CO₂ storage and unloading system, absorbent circulation system, decarbonization agent storage and supply system, steam heating system, auxiliary system, etc.

(2) Combustion unit means engines, boilers and/or other combustion device (excluding incinerators) that use carbonaceous fuels on board the ships.

(3) Chemical absorption method means a type of method that absorbs CO₂ in the form of a chemical reaction through a chemical absorbent and desorbs CO₂ in the form of a chemical reaction under specific conditions.

(4) Decarbonization agent means various chemical substances that use chemical absorption method to remove CO₂ from the exhaust gas of combustion unit, such as organic amine, calcium oxide, etc., and it refers to organic amine in this Guidelines.

(5) Absorbent means a solution formed by mixing decarbonization agent with water in a certain proportion.

(6) Rich solution means the solution formed by an absorbent after absorbing CO₂ within the absorber unit.

(7) Lean solution means the solution formed by separating CO₂ from a rich solution through a desorber unit.

(8) Absorber unit means a system that captures and absorbs CO₂ from the exhaust gas of combustion unit on board the ships, generally consisting of exhaust cooling units, CO₂ absorption towers, nozzles, additional pipelines, etc.

(9) Desorber unit means a system that desorbs gaseous CO₂ from a rich solution through heating, generally consisting of a desorption tower, reboiler, nozzles, CO₂ cooling unit, additional pipelines, etc.

(10) OCCS residue means the substances separated from the absorbent filters or other residues generated by OCCS.

(11) CO₂ compression and liquefaction system means a system composed of compressor, gas-liquid separator, heat exchanger (condenser), etc., used for CO₂ liquefaction.

(12) Exhaust cooling unit means a device that reduces the inlet exhaust temperature of the absorption tower through pre-washing or heat exchange, etc.

(13) Reboiler means a device that uses heat exchange and other methods to reach the desorption temperature again for the rich solution and the Rich solution that has not been fully decomposed and absorbed.

(14) Absorbent circulation system means the one between the absorber unit and desorber unit, generally consisting of absorbent circulation pump, absorbent filter, lean/rich solution heat exchanger, lean solution cooling unit, circulation chamber, pipeline, etc.

(15) Decarbonization agent supply system means the supply system for refueling, storing, and transporting decarbonization agents to the absorbent circulation system, generally consisting of decarbonization agent storage tanks, pumps, valves, decarbonization agent concentration control system, refueling and transportation pipelines, etc.

(16) CO₂ storage and unloading system means the system for storing and unloading liquid CO₂ on board the ship, generally consisting of CO₂ storage tanks and their containment system, CO₂ unloading devices, associated pipelines and control system, etc.

(17) Gas and liquid separator means the equipment used to separate and remove liquid from CO₂ gas.

(18) Triple point means the points at which temperature and pressure are at a thermodynamic equilibrium in which three phases of gas, liquid and solid CO₂ exist together.

(19) OCCS control station means the space where control, monitoring, alarm, display, safety protection and other devices related to OCCS are centrally arranged.

1.3.2 The abbreviations and symbols are explained as follows:

(1) OCCS means the onboard carbon capture system.

(2) SCR means the selective catalytic reduction.

(3) EGCS means the exhaust gas cleaning system.

1.4 Class notations

1.4.1 Ships installed with onboard carbon capture system and in compliance with the relevant requirements of Chapters 1 to 8 of this Guidelines are to be assigned with the class notation OCCS upon the application and satisfaction survey.

1.4.2 OCCS ready ships are to be assigned with class notations OCCS Ready 1, OCCS Ready 2 or OCCS Ready 2 (X) after confirming that the ships are in compliance with the relevant requirements of Chapter 9 of this Guidelines, with the following specific meanings:

(1) OCCS Ready 1: design and approval of principle drawings are carried out for OCCS ready ship to ensure that the ship is in compliance with the basic requirements for future installation of OCCS, and that no equipment or systems related to carbon capture systems have actually been installed on board;

(2) OCCS Ready 2: design and approval of detailed drawings are carried out for OCCS ready ship to ensure that the OCCS ready is in compliance with the relevant requirements of this Guidelines, and that no equipment or systems related to carbon capture systems have actually been installed on board;

(3) OCCS Ready 2 (X): on the basis of meeting the requirements of OCCS Ready 2, the OCCS related equipment and systems have actually been installed on board the ship. The symbol X represents one or more suffixes of class notation, with the following specific meanings:

- ① The hull structures and related supporting structures have been strengthened, represented by the capital letter S;
- ② The absorption tower, desorption tower and absorbent circulation system have been installed, represented by the capital letter A;
- ③ The CO₂ compression and liquefaction system has been installed, represented by the capital letter L;
- ④ The CO₂ storage tanks have been installed, represented by the capital letter T.

1.5 Plans and information

1.5.1 For ships installed with OCCS, in addition to the plans and information required in the relevant requirements of CCS rules and guidelines, the followings are also to be submitted to CCS for approval:

(1) Piping system related to OCCS, mainly including:

- ① Exhaust piping system;
- ② Cooling water piping system;
- ③ Absorbent circulation system pipeline;
- ④ Absorbent purification pipeline (if application);
- ⑤ Steam piping system (if application);
- ⑥ Tank ventilation pipes;
- ⑦ CO₂ compression and liquefaction storage pipeline;
- ⑧ Decarbonization agent supply system pipeline.

(2) Hazardous area divisions (if applicable);

(3) Arrangement of electrical equipment in hazardous areas (if applicable);

(4) Power load calculation sheet;

(5) Arrangement of ventilation;

(6) Detailed list of monitoring, alarms and safety protection;

(7) OCCS electrical system;

(8) Gas detection system and arrangement.

1.5.2 For ships installed with OCCS, in addition to the plans and information required in the relevant requirements of CCS rules and guidelines, the followings are also to be submitted to CCS for information:

(1) OCCS technical description and installation plan, mainly including system design parameters, compatibility with combustion unit, list of systems and equipment, system arrangement plan, CO₂ capture capacity calculation sheet for the system, etc.;

(2) Explanation on the working principle and flowchart of OCCS;

(3) Arrangement of OCCS system and equipment;

(4) Risk assessment report;

(5) Arrangement of CO₂ storage tanks;

(6) Arrangement of CO₂ unloading system;

(7) OCCS operation and maintenance manual;

(8) Decarbonization agent safety data sheet (MSDS), including but not limited to physical and chemical characteristics, first aid measures, fire protection measures, leakage emergency response, operational disposal and storage, personal protective measures, stability and reactivity, toxicological information, etc;

(9) OCCS steam consumption calculation sheet (if applicable).

1.5.3 Additional drawings and data are to be required to submit if CCS deems necessary.

1.6 Risk assessment

1.6.1 A necessary risk assessment intends to conduct for eliminating or mitigating all adverse effects arising from the installation of OCCS on persons on board, the environment, and the structural strength and integrity of the ship.

1.6.2 The risks are to be analyzed using acceptable and recognized risk analysis techniques, and the followings are to be taken into account:

(1) Adaptability to environmental and working conditions;

(2) Impact on the safe operation of combustion unit and power plant;

(3) Accidental accumulation or diffusion of flammable, explosive, and toxic gases;

- (4) Leakage and diffusion of chemical substances;
- (5) Possible injuries to crew members or other equipment caused by high/low temperature, high pressure, and operating equipment;
- (6) Potential fire risks;
- (7) The CO₂ suffocation risk.

1.6.3 In general, the risk assessment report is to address the following contents:

- (1) Standards and methods used for risk analysis;
- (2) Various assumptions and prerequisites provided during analysis;
- (3) Analyzing objects such as system, equipment, operation, etc;
- (4) Possible risks;
- (5) Causes for risks;
- (6) Potential impact of risks;
- (7) Measures taken to prevent or mitigate risks and hazards and the implementation.

1.7 Operation and maintenance manual

1.7.1 OCCS operation and maintenance manual that has been reviewed by CCS is to be available on board the ship. The manual is to address operation, safety, maintenance requirements, and occupational health risks related to the system.

1.7.2 The manual is to include the followings, as a minimum:

- (1) Procedures and plans related to OCCS operation, survey, testing and maintenance;
- (2) Procedures and plans related to regular testing and maintenance of detection system and safety shutdown system;
- (3) Special instructions on refueling, storage, and use of hazardous and non-hazardous chemicals intended for system operation;
- (4) Various conditions related to system operation, etc;
- (5) Emergency handling procedures, such as operating procedures for emergency shutdown, exhaust bypass and isolation, absorbent leakage, CO₂ leakage, emergency cleaning, ventilation and protection, as well as the arrangement for responsible personnel, etc.;
- (6) Training and routine maintenance records, etc.

Chapter 2 Design and Arrangement

2.1 General provisions

2.1.1 The OCCS is to be designed and arranged to meet the followings:

- (1) The system design is to be applicable to the operating environment onboard the ship;
- (2) The strength and tightness design of the system are to meet the required fluid characteristics for processing;
- (3) The system is to have redundant safety and protection measures and the capability to prevent and handle unexpected events.

2.1.2 Ductility, corrosion resistance and possibility of hazardous reactions under working temperature and pressure are to be taken into account for the main equipment and associated piping materials of OCCS. Material that directly contact with absorbent is to be compatible with it, or appropriate anti-corrosion coating is to be used. The materials (including coatings) used for equipment, pipelines and components in contact with seawater are to be harmless to marine organisms.

2.1.3 The CO₂ storage, pressure release, control and monitoring system are to be designed to take into account the composition, moisture content, expected impurities of liquid CO₂ and respective impact on the triple point of CO₂.

2.1.4 Where other exhaust gas post-treatment units (such as EGCS, SCR) are installed, their compatibility with OCCS are to be considered.

2.1.5 The structural design and arrangement of OCCS are to facilitate for installation, operation and maintenance.

2.2 Ship arrangement

2.2.1 The CO₂ storage tank space is to be isolated from the machinery space, accommodation spaces, service space, control station, cable locker, domestic water tank and storage tank by means of cofferdam tank, oil fuel tank or bulkhead meeting with the airtightness requirement of A-0 class division.

2.2.2 Sealing device is to be provided in way of the openings for CO₂ cargo containment system on the open deck.

2.2.3 In order to prevent CO₂ from entering accommodation space, service space, machinery space, control station, etc., the impacts of CO₂ pipeline, CO₂ storage tank ventilation system and exhaust gas emitted by gas combustion unit in the machinery space on the aforementioned spaces are to be considered when determining the positions of air inlet/outlet and openings in these spaces.

2.2.4 All air inlets, outlets, and other openings in accommodation space, service space and control station (excluding CO₂ storage areas) are to be provided with shut-off devices. The devices are to be capable of operating both externally and internally in these spaces that are frequently accessed with a risk of CO₂ entry.

2.2.5 Proper ventilation is to be provided in the space where the CO₂ compression and liquefaction equipment is located. Where the equipment is arranged in a separate compartment, the common bulkheads between the compartment and other enclosed spaces such as machinery space, accommodation space, service space and control station are to be kept airtight and are not to be directly entered from the aforementioned spaces.

2.2.6 The machinery space serving for CO₂ storage and unloading is to be so arranged to allow personnel wearing protective clothing and respirators to enter and exit safely and unobstructed, and to promptly rescue injured personnel in the event of injury. At least two escape routes and doors away from each other are to be provided within the machinery space. Single escape route is not acceptable unless the maximum distance from any point to the door within the space is less than or equal to 5 m.

2.2.7 All valves required for CO₂ unloading are to be accessible and operated by personnel wearing protective clothing. Drainage devices that are not directly connected to other spaces are to be provided in the spaces where CO₂ compression and liquefaction equipment and storage tanks are located.

2.2.8 Access is to be provided for inspecting the insulation of CO₂ storage tanks.

2.2.9 The CO₂ storage spaces and void compartments are to be arranged to allow personnel wearing breathing apparatus to enter these spaces for inspection, and allow the injured and/or unconscious personnel to evacuate.

2.2.10 Requirements for arrangement of CO₂ storage tanks:

(1) Where the CO₂ storage tanks are arranged on the open deck, the impacts on the bridge room visibility and the safety access for crew members are to be considered;

(2) Where the CO₂ storage tanks are arranged below the open deck, suitable drainage devices that are not connected to the machinery space are to be provided in the storage space and leakage detectors are to be provided;

(3) The location of CO₂ storage tanks is to be so arranged to reduce the probability of damage of the tanks in the event of minor ship collision damage to the minimum level.

2.2.11 Drip trays are to be provided at locations where liquid CO₂ may leak, and monitoring and alarms are also to be provided.

2.3 Strength and stability

2.3.1 Ships installed with OCCS are to meet the applicable requirements of longitudinal strength and local strength specified in the CCS Rules.

2.3.2 The structural strength evaluation of CO₂ storage tanks and their supporting structures is to meet the applicable requirements of Appendix 2, Chapter A4, PART TWO in the Rules for Construction and Equipment of Ships Carrying Liquefied Gases in Bulk (the CCS Rules for Liquefied Gases in Bulk). For independent C-type twin and/or triple tanks, the applicable requirements of Appendix 3, Section 5 of the CCS Rules for Liquefied Gases in Bulk are also to be met.

2.3.3 Impacts of wind area, empty ship center of gravity, heel and trim on hull stability and number of outfittings, as well as the potential impacts of changes in tonnage on the applicable statutory standards are to be taken into consideration for the ships installed with OCCS.

2.3.4 The impact of the weight and center of gravity changes of CO₂ captured during the navigation on hull stability is to be taken into account.

2.4 Compatibility with combustion unit

2.4.1 OCCS is to be applicable to the flow volume, temperature, back pressure, SO_x concentration, particle size, etc. of the exhaust gas from combustion unit connected, and treatment of partial

volume of the exhaust gas is permitted. The relevant operation conditions, restrictions, exhaust gas treatment capacity, etc. are to be clearly specified in the operation manual.

2.4.2 OCCS is to be compatible with the connected combustion unit, and the relevant technical specifications are to be submitted for review.

2.5 Exhaust gas back pressure

2.5.1 After OCCS is installed onboard a ship, the exhaust gas back pressure is always to be maintained within the range specified by the combustion unit manufacturer under various operating conditions.

2.5.2 Where a fan is installed to maintain the required back pressure, measures are to be taken to ensure that even if the fan fails, the connected combustion unit can still normally operate. In the case of multiple combustion units sharing a common OCCS, the fan is to be provided by the consideration of back pressure requirements of all connected combustion units.

2.5.3 Appropriate measures are to be taken to reduce the risk of corrosion and blockage affecting the normal operation of fans (if provided).

2.6 Exhaust bypass or equivalent measures

2.6.1 The OCCS system is to be designed and arranged to ensure that the combustion units can still operate normally in the event of its failure or normal shutdown.

2.6.2 For the purpose of the achievement of the objective specified in 2.6.1 of this Guidelines, the bypass device are provided to meet the following requirements:

- (1) Means are provided in local and remote control position to correctly indicate the working conditions;
- (2) Reliable operation, ensuring the safe operation of the combustion unit under any circumstances;
- (3) A safety interlock device is to be provided between the bypass valve and the relevant inlet valve of the OCCS absorber unit to ensure that the exhaust gas of combustion unit can be smoothly emitted under any circumstances;
- (4) The actions are to be automatically initiated according to the requirements of Table 7.2.4 in Chapter 7 of this Guidelines.

2.6.3 Where a bypass is not provided for the OCCS system, it is to be ensured that even washwater sprinkling is stopped within the OCCS absorber unit, high temperature exhaust gas generated by the FOCU can also be emitted smoothly without causing damages to the OCCS system and its components or affecting the continuous safe operation of the FOCU. Under such circumstance, the design of the OCCS system is to fully consider risks such as the fire, soot accumulation and carbonization due to direct erosion of the high temperature exhaust gas and appropriate measures are to be taken to control such risks.

2.7 Interconnections of exhaust gas piping

2.7.1 Normally, exhaust pipes from FOCUs are to be routed separately and not interconnected. However, interconnected exhaust piping systems to a common OCCS unit may be accepted subject to the agreement of CCS if the designer takes full consideration of the potential risks and makes effective isolation arrangements preventing the exhaust gas from flowing back or leaking to the stopped FOCU(s) or other spaces.

2.7.2 A safety interlock device is to be provided between the starting device and the isolation device for remotely controlled or automatically started FOCU(s) to prevent the isolated FOCU(s) from being started when the isolation device is in the closed condition.

2.7.3 The isolation device is to work reliably and failure of the isolation device under any circumstances is to ensure the safe operation of the FOCU(s).

2.8 Electrical installations

2.8.1 The electrical load of OCCS is to be included in the global ship electrical load estimation, which can be included in the "Electrical Load Estimation of Main and Emergency Power Supply" required to be submitted for approval in 1.1.3.1, Chapter 1 of PART FOUR in the CCS Rules. The capacity of the main power supply on board the ship is to enable the continuous operation of the OCCS system during normal navigation, and is also to meet the requirements of 2.1.1.1, Chapter 2 of PART FOUR in the CCS Rules.

2.8.2 The selection of enclosure protection type for electrical equipment related to OCCS is to be suitable for the installation location, and its minimum protection grade is to meet the requirements of Table 1.3.2.2, Chapter 1 of PART FOUR in the CCS Rules.

2.8.3 All feeder circuits are to be protected against overload and short circuits by a multi-pole circuit breaker arranged to interrupt simultaneously all insulated poles, or a multi-pole switch with fuses, and are also to meet the requirements of 2.5.9, Chapter 2 of PART FOUR in the CCS Rules.

2.8.4 In addition to the provisions of 2.8.1 ~ 2.8.3 in this Guidelines, the OCCS electrical equipment is to comply with the applicable requirements of Chapter 2 of PART FOUR in the CCS Rules.

2.9 Explosion protection

2.9.1 A safety data sheet for decarbonization agents are to be provided. Where the decarbonization agents emit flammable and explosive gases, hazardous areas are to be classified in accordance with the requirements of IEC6007-10-1 "Explosive atmospheres - Classification of areas - Explosive gas atmospheres" and IEC60079-502 "Electrical installations in ships - Tankers - Special features".

2.9.2 For electrical equipment installed in hazardous areas, the appropriate certified explosion-proof equipment is to be selected in accordance with the category of hazardous areas, and the explosion group and temperature class are to meet the safety data sheet of CO₂ absorbents.

Chapter 3 CO₂ Absorption and Desorption

3.1 General provisions

3.1.1 This Chapter applies to the design and application of systems and equipment related to CO₂ absorption and desorption (the systems and equipment) onboard the ships.

3.1.2 The operation conditions of the system and equipment are to meet the applicable requirements of Section 2, Chapter 1 of PART THREE, Section 2, Chapter 1 of PART FOUR and Section 1, Chapter 2 of PART SEVEN in the CCS Rules.

3.1.3 The materials of the system and equipment are to meet the applicable requirements of the CCS Material Rules, and directly or indirectly (through appropriate protective measures such as coatings and linings) applicable to the characteristics of the working medium under predictable temperature and/or pressure conditions.

3.1.4 The pressure vessels and heat exchangers inside the system and equipment are to meet the applicable requirements of Chapter 6 of PART THREE in the CCS Rules.

3.1.5 The system and equipment are to be provided with protective measures in accordance with the applicable requirements of 1.3.6, Chapter 1 or PART THREE in the CCS Rules.

3.1.6 Absorbent leakage monitoring and alarm are to be provided.

3.1.7 In case there is significant risk of fire and/or toxicity after the leakage of absorbent, special consideration is to be given to on the system and equipment arrangement on board the ship, ventilation of spaces and safety measures.

3.2 Absorber unit

3.2.1 The absorber unit is to be considered as a constituent part of the combustion unit exhaust gas system.

3.2.2 Unless effective measure, such as bypass device, is provided to prevent overheating, all components, that may contact with exhaust gas, are to enable withstanding all possible exhaust gas high temperatures.

3.2.3 The components in contact with lean solution or rich solution are to be made of corrosion-resistant stainless steel or other corrosion-resistant materials, and are to enable withstanding the pH and temperature changes of lean solution or lean solution and other media that may contact with.

3.2.4 Exhaust cooling units

(1) Capable of meeting the exhaust gas cooling capacity requirements under the maximum working load of CO₂ absorption tower, and adjusting the exhaust output temperatures to meet the settings of CO₂ absorption tower;

(2) Pressure and temperature monitoring and alarms are to be provided on its exhaust gas inlets and outlets according to Table 7.2.4 of this Guidelines;

(3) Where the exhaust gas outlet temperature exceeds the setting, the associated safety action is to be activated according to the requirements of Table 7.2.4 of this Guidelines, unless the absorption tower can withstand the expected high temperature effect of the exhaust gas;

(4) The cooling water discharge of cleaning type exhaust gas cooling unit is to meet the relevant requirements of 2.6, Chapter 2 in the Guidelines for Application of Exhaust Gas Recirculation (EGR) Systems Onboard Ships.

3.2.5 Absorption tower

- (1) The absorption tower and its internal structures are to be designed by taking consideration of corrosion, flushing, backflow, leakage, etc;
 - (2) The exhaust gas inlet or its pipeline is to be so designed to prevent liquid backflow from the tower into external exhaust gas inlet pipeline, and the appropriate liquid level monitoring may be provided for this purpose;
 - (3) Pressure and temperature monitoring and alarms are to be provided according to Table 7.2.4 of this Guidelines, and if necessary, associated safety actions are to be activated;
 - (4) Necessary measures are to be taken to separate the gas and liquid;
 - (5) Measures are to be taken to monitor the absorption effect, such as monitoring the difference of CO₂ concentrations of the exhaust gas before and after passing through the absorption tower;
 - (6) Liquid level monitoring and alarm are to be provided according to Table 7.2.4 of this Guidelines, and the alarm points are to be provided by taking the consideration of the angles of heeling, trim, rolling and pitch during the ship operation; If necessary, associated safety actions are to be activated;
 - (7) The absorbent nozzles are to be designed and arranged to take account of the risks of scaling and blockage, and if necessary, appropriate flushing measures are to be taken;
 - (8) Suitable manholes/inspection holes, accesses or platforms are to be provided, and spaces are to be left around the absorption tower for parts and components renewal, maintenance, and cleaning.
- 3.2.6 The absorption tower and its hull support structures are to enable withstanding various loads under normal ship operating conditions.

3.3 Absorbent circulation system

3.3.1 An absorbent circulation tank with appropriate capacity or other equivalent measures is to be provided, and it is to meet the following requirements:

- (1) The tank capacity is at least to meet the expected longest continuous operating duration of OCCS;
- (2) Temperature and liquid level monitoring and alarms are to be provided according to Table 7.2.4 of this Guidelines;
- (3) The lean solution circulation tank is to be provided with absorbent condition monitoring (such as pH value).

3.3.2 An absorbent circulation pump with a capacity meeting the absorbent circulation requirements under the maximum load of the OCCS system is to be provided.

3.3.3 Where a gravity type is used, the absorbent pipeline from absorption tower/desorption tower to absorbent circulation tank is to be so arranged to facilitate for gravity discharge, taking the consideration of the alarming liquid level of the absorption tower/desorption tower, gas escape and siphon effect.

3.3.4 Absorbent filters or equivalent measures are to be provided for the rich solution circulation or treatment pipelines, and the filtered residues are to be discharged into the OCCS residue tank.

3.3.5 OCCS residue tank:

- (1) The tank capacity is to meet the maximum residue generated by the absorbent filters during the expected longest operating duration of OCCS;
- (2) High liquid level alarms are to be provided;
- (3) Residue discharge pumps and shore pipelines are to be provided.

3.3.6 Both the absorbent circulation tank and OCCS residue tank are to be provided with appropriate cleaning and discharging measures.

3.3.7 The air pipes of the absorbent circulation tank and OCCS residue tank are to meet the requirements of 4.2.5 and 4.2.6 of this Guidelines.

3.3.8 Necessary degassing and ventilation are to be provided for absorbent circulation tanks and OCCS residue tanks that need internal maintenance.

3.3.9 Drip tray is to be provided at the possible leakage location in the absorbent circulation system. Discharging device is to be provided for drip tray so that the absorbents can be discharged to OCCS residue tank, and check valve is to be fitted on the discharge pipeline.

3.3.10 Check devices are to be provided on the fresh water supply pipelines leading to tanks and processing equipment containing absorbents.

3.3.11 The lean/rich solution heat exchanger and lean solution cooling unit are to be provided with temperature and pressure monitoring and alarms according to Table 7.2.4 of this Guidelines.

3.4 Desorber unit

3.4.1 All components of the desorber unit are to be unable withstanding all possible high temperatures.

3.4.2 The components in contact with lean or Rich solutions are to be made of corrosion-resistant stainless steel or other corrosion-resistant materials, and are to be able withstanding the pH and temperature changes of lean or rich solution and other media that may contact with.

3.4.3 Desorption tower

(1) The desorption tower and its internal structures are to be designed by taking consideration of corrosion, flushing, backflow, leakage, etc;

(2) Temperature, liquid level and pressure monitoring and alarms are to be provided according to Table 7.2.4 of this Guidelines, and the alarm points for liquid level are to be provided by taking the consideration of the angles of heeling, trim, rolling and pitch during the ship operation;

(3) The absorbent nozzles are to be designed and arranged to take account of the risks of scaling and blockage, and if necessary, appropriate flushing measures are to be taken;

(4) Suitable manholes/inspection holes, accesses or platforms are to be provided, and spaces are to be left around the desorption tower for parts and components renewal, maintenance, and cleaning.

3.4.4 Reboiler

(1) Temperature and pressure monitoring is to be provided for the absorbent and heating medium pipelines between the reboiler and desorption tower according to Table 7.2.4 of this Guidelines;

(2) The effect of heating temperature on the volatility of the absorbent is to be taken into consideration.

3.4.5 CO₂ cooling unit and gas-liquid separator are generally to be provided on the gas treatment pipeline after the desorption tower.

3.5 Cooling water system

3.5.1 The cooling water system (used for exhaust gas cooling unit, lean solution cooling unit, CO₂ cooling unit, etc.) are to meet the applicable requirements of PART THREE in the CCS Rules.

3.5.2 The capacity of cooling water pump is to meet the cooling water demand of OCCS at maximum working load, and not to affect the cooling water demand of critical systems such as propulsion.

3.6 Piping system

3.6.1 The piping system is to be designed to meet the applicable requirements of PART THREE in the CCS Rules.

3.6.2 Unless a clear difference between the absorbent and decarbonization agent is provided, the design of piping system related to absorbent is also to meet the applicable requirements of that related to decarbonization agent specified in Chapter 4 of this Guidelines.

Chapter 4 Decarbonization Agent Supply System

4.1 General provisions

4.1.1 The material, design, installation and arrangement, etc. of the decarbonization agent supply system (including pipelines, valves, joints) are to meet the applicable requirements of Chapters 1 and 2 of PART THREE in the CCS Rules.

4.1.2 Pipelines and tanks related to filling, storage, transportation and treatment of decarbonization agents, as well as any other components that may contact with decarbonization agents, are to be made of corrosion-resistant stainless steel materials or other corrosion-resistant materials that can withstand acid and alkali corrosion of the medium which may be contacted with.

4.1.3 The decarbonization agent supply pipelines are to be independent of other piping systems on board and not to be provided in or pass through the accommodation spaces, service spaces, and control stations.

4.1.4 The decarbonization agent supply pipelines are not to be arranged above the boiler or near steam piping, exhaust piping or hot surfaces requiring insulation.

4.1.5 Drip trays are to be provided for decarbonization agent storage and supply pipeline at the possible leakage locations to accommodate the leaked agent.

4.1.6 Discharge device is to be provided for the drip tray to discharge the decarbonization agent in the tray to the overflow tank or other suitable tanks (such as OCCS residue tank), and a check valve is to be fitted on the discharge pipeline. Alternatively, a leakage monitoring device and a quick-closing valve are to be provided to quickly and automatically cut off the decarbonization agent transportation in the case of leakage. When this arrangement is used, the capacity of the drip tray is to be sufficient to accommodate the possible leakage.

4.1.7 Appropriate protective measures are to be taken in accordance with the requirements of 1.3.6, Chapter 1 of PART THREE in the CCS Rules to prevent potential harm to personnel onboard during the filling and maintenance of decarbonization agent storage tanks.

4.2 Storage of decarbonization agent

4.2.1 The capacity of decarbonization agent storage tank is to be so designed to at least meet the decarbonization agent consumption required for the maximum navigation duration between ports where the decarbonization agent may be filled by taking the consideration of the factors such as intended ship route, CO₂ capture capacity per time unit, decarbonization agent consumption rate, etc. If no accurate data of navigation duration are provided, it may be calculated as 30 days.

4.2.2 The decarbonization agent storage tanks are to be far away from heat sources, arranged in a well ventilated area, and not to be directly adjacent to the fuel tanks and fresh water tanks.

4.2.3 Where a decarbonization agent storage tank is arranged in an independent enclosed compartment, airtight bulkheads are to be used for isolation to prevent leaked decarbonization agents from entering other compartments. The bulkheads of the tank can be used for penetrating cables and piping systems, and are also to meet the requirements of airtightness structure. The distance between the bulkhead and the shell plating of hull is not to be less than 760mm.

4.2.4 The compartment where the decarbonization agent storage tank is located is to be provided with a negative pressure mechanical ventilation system independent of other spaces onboard the ship, with the air changes not less than 30 times per hour. The outlet of ventilation system is to be

generally arranged in accordance with the decarbonization agent safety data sheet (MSDS).

4.2.5 Air pipes are to be fitted with for decarbonization agent storage tank in accordance with the requirements of Section 10, Chapter 3 of PART THREE in the CCS Rules. The outlets of air pipes are to be located in a safe area on the open deck and not easily accessible to personnel, and effective measures are to be taken to prevent water from entering the tank. The air pipes are to be independent of other piping or systems onboard the ship.

4.2.6 The air pipe outlet positions in the decarbonization agent storage tank are to meet the following requirements:

- (1) At least 6 m above the open deck;
- (2) 10 m distanced from the inlets and openings of the nearest accommodation spaces, service spaces and control stations.

4.2.7 The decarbonization agent tank, pipeline/piping system are to be made of steel or other equivalent materials with a melting point higher than 925 °C.

4.2.8 The ventilation requirements in 4.2.4 of this Guidelines are also applicable to the adjacent enclosed compartments that are usually manned:

- (1) Where it is adjacent to the compartment where the decarbonization agent tank is located, with potential leakage points from that compartment (such as manholes, connectors); or
- (2) Where the decarbonization agent transporting system passes through these compartments, the ventilation system specified in 4.2.4 of this Guidelines is not to be provided, unless the transporting system is made of steel or other equivalent materials with a melting point higher than 925 °C and has fully welded joints.

4.2.9 Excessively high or low temperatures may affect the performance of decarbonization agent. Necessary heating and/or cooling systems are to be provided to decarbonization agent storage tanks based on the ship navigation routes or operating areas, as well as the storage temperature range of decarbonization agent.

4.2.10 Where the pipeline leading from the decarbonization agent storage tank is damaged and causes the decarbonization agent to flow out, a quick closing valve is to be provided to the rigid duct on the bulkhead of storage tank, and the length of the rigid duct is to meet the applicable requirements of 4.2.5.2 of PART THREE in the CCS Rules. In addition to being capable of closing locally, the quick closing valve is also to be remotely closed in a safe location that is easily accessible outside the storage tank.

4.2.11 The decarbonization agent storage tank is to be so arranged to empty the decarbonization agent inside the tank and degassing the tank through a portable or fixed system.

4.2.12 The entrance/access of the compartment where the decarbonization agent storage tank is located is to meet the following requirements:

- (1) At least two entrance/access doors are to be provided and arranged as far apart as possible. At least one entrance/access door is directly to lead to the open deck; Access doors that do not directly lead to the open deck is to be airtight and self closing;
- (2) The access doors are to be easy to operate and open outward;
- (3) The access is not to be directly connected to that of the accommodation space.

4.2.13 The compartment where the decarbonization agent storage tank is located is to be provided with an independent bilge water discharge system to ensure that these bilge water does not flow into the open bilge well or the bilge water system of other compartments.

4.2.14 The air pipes, filling pipes, measuring pipes and transportation pipelines of the

decarbonization agent storage tank are not to pass through accommodation spaces, service spaces and control stations, unless reliable leak prevention measures are taken, such as double-wall pipes are used for protection.

4.2.15 According to the parameters of decarbonization agent safety data sheet (MSDS), a set of fixed combustible and/or toxic gas detection system (if applicable) is to be provided in each compartment where decarbonization agent storage tank is located.

4.2.16 In addition to emergency lighting, the lighting in the compartment where the decarbonization agent storage tank is located is to be interlocked with ventilation, and the ventilation system is to start when the lighting is turned on. The failure of the ventilation system is not to turn off the lighting.

4.3 Filling of decarbonization agent

4.3.1 The filling open ends of decarbonization agent is to be located on the open deck and provided with relevant closing valves and blind flanges. The filling open ends and filling pipelines located on the open deck are to be identified. Drip trays are to be provided at the filling open ends or other possible leakage locations.

4.3.2 The filling pipeline of decarbonization agent is to be arranged above the decarbonization agent storage tank and as close as possible to the decarbonization agent storage tank. The decarbonization agent filling pipeline and its arrangements are to be reasonably designed to prevent the decarbonization agent from staying in the filling pipeline after use or when not in use.

4.4 Filter

4.4.1 To reduce the damage of impurities to valves and other critical components of the decarbonization agent supply system, filters are to be installed in the decarbonization agent supply system.

4.4.2 The design pressure of the filter is to be greater than the maximum working pressure of the decarbonization agent supply system.

4.5 Decarbonization agent overflow tank

4.5.1 The decarbonization agent overflow tank is to be arranged below the decarbonization agent storage tank to collect the overflow decarbonization agent after filling.

4.5.2 The decarbonization agent in the overflow tank is not to be discharged overboard without treatment.

4.5.3 The air pipes of the overflow tank can be connected to the air pipeline of the decarbonization agent storage tank.

4.5.4 For the convenience of maintenance, it is necessary to temporarily remove the decarbonization agent from the decarbonization agent supply piping system. A decarbonization agent discharge pipeline is to be provided between the bottom of decarbonization agent transportation pipeline and the decarbonization agent overflow tank, and a shut-off valve is to be installed. The capacity of the decarbonization agent overflow tank is to be sufficient to accommodate the maximum decarbonization agent stored in the transportation pipeline between the main valve of the decarbonization agent storage tank and absorbent circulation system.

4.6 Protection measures

4.6.1 Relevant safety instructions, including MSDS for decarbonization agents, is to be posted near to the entrance of the compartment where the decarbonization agent storage tank is located.

4.6.2 To protect crew members, appropriate protective equipment (including aprons, long sleeved rubber gloves, rubber boots, overall made of chemical-resistant materials, masks, chemical-resistant goggles or masks) are to be equipped onboard the ship. At least three sets of protective equipment are to be provided onboard the ship, and these equipment are to be stored in the dedicated storage tanks that is easily accessible outside the accommodation space.

4.6.3 At least the following emergency equipment are to be provided inside the dedicated storage tanks that is easily accessible outside the decarbonization agent storage tank:

- (1) Self-contained breathing apparatus (capable of supplying for at least 30 minutes), 3 sets;
- (2) Eye wash solution, 3 boxes;
- (3) Boric acid, 250ml/bottle, 3 bottles;
- (4) Stretcher, 1 pair.

4.6.4 Eye flushing device and shower facilities are to be provided near the main filling decarbonization agent pipes and pumps.

Chapter 5 CO₂ Compression and Liquefaction

5.1 General provisions

5.1.1 This Chapter applies to the arrangement and design of CO₂ compression and liquefaction systems onboard the ships.

5.1.2 CO₂ pressure vessels are to meet the requirements of Chapter 6 of PART THREE in the CCS Rules. The CO₂ pressure vessels mentioned in this Chapter include surge tanks, heat exchangers and pressure accumulators for processing liquid or gaseous CO₂.

5.1.3 The requirements for C-type independent liquid cargo tanks in Chapter 4 of PART THREE in the CCS Rules for Liquefied Gases in Bulk can be applied to liquid CO₂ pressure vessels.

5.1.4 The CO₂ pipeline is to meet the applicable requirements of Chapter 5 of the CCS Rules for Liquefied Gases in Bulk, and the liquid and gaseous CO₂ pipeline is also to meet the Grade I pipeline requirements of Chapter 2 of PART THREE in the CCS Rules.

5.1.5 The CO₂ compression and liquefaction system and equipment are to be arranged to meet the requirements of 2.2.5 in this Guidelines. Where a liquid CO₂ storage tank is provided in the liquefaction unit, the unit is also to be arranged in accordance with the relevant CO₂ storage tank requirements of 2.2 of this Guidelines.

5.1.6 Drip trays are to be provided at possible liquid CO₂ leakage locations and leakage monitoring and alarm are to be provided.

5.1.7 The CO₂ compression and liquefaction systems are to be designed to take into consideration the following factors:

- (1) Preventing the leakage of gaseous and liquid CO₂ caused by abnormal conditions;
- (2) Suffocation risk for personnel exposed to high CO₂ concentration environments;
- (3) Low-temperature impact of liquid CO₂ leakage on the hull, equipment and personnel.

5.2 Compression and liquefaction

5.2.1 The processing capacity of the compression and liquefaction systems are to meet the CO₂ compression and liquefaction requirements under the maximum working load of OCCS.

5.2.2 Necessary gas-liquid separators (such as separating absorbents, water, oil, etc.) are to be provided.

5.2.3 In general, surge tank is to be provided in front of the compressors. Where a two-stage process of compression and heat-exchanging liquefaction is used, surge tank is generally also to be provided between the compressors and the liquefaction unit.

5.2.4 The surge tank is to be provided with temperature and pressure monitoring and alarm in accordance with Table 7.2.4 of this Guidelines.

5.2.5 The enclosed space where compression and liquefaction equipment are located is to be equipped with CO₂ and O₂ concentration monitoring and alarm in accordance with Table 7.2.4 of this Guidelines for the space where CO₂ storage tanks are located.

5.3 Piping system

5.3.1 The CO₂ pipelines are not to pass through the accommodation spaces, service spaces and control stations.

5.3.2 Except for the connections of equipment, valves, and instrument accessories, CO₂ pipelines are to be connected by welding as much as possible.

5.3.3 The effects of temperature stress are to be taken into consideration for the liquid CO₂ pipeline and its supporting.

5.3.4 The liquid CO₂ pipelines are to be provided with necessary safety relief devices with its outlet led to the areas on open deck.

5.3.5 The liquid CO₂ pipelines are to be wrapped with thermal insulation.

5.4 Ventilation

5.4.1 The ventilation of the enclosed space, where the CO₂ compression and liquefaction equipment is located, is to meet the relevant requirements of 6.3.2 of this Guidelines.

Chapter 6 CO₂ Storage and Unloading

6.1 General provisions

6.1.1 In addition to the provisions of this Chapter, CO₂ storage and unloading are to meet the relevant requirements of ports and competent authorities.

6.1.2 The pressure and temperature of CO₂ storage tanks are to be maintained during the CO₂ storage and unloading to prevent the impact of pressure-loss solidification on the hull structures and the harm of overpressure gasification leakage to personnel.

6.2 Containment system of CO₂ storage tanks

6.2.1 The integral cargo tanks, membrane/semi-membrane cargo tanks, or Type A/Tape B diamond-shaped independent cargo tanks are not to be used as CO₂ storage tanks.

6.2.2 The containment system of CO₂ storage tanks is to meet the requirements of Section 6, Appendix 4 of PART TWO in the CCS Rules for Liquefied Gases in Bulk.

6.2.3 The triple point is to be determined based on the captured CO₂ purity. The design temperature and pressure of CO₂ storage tanks is to be fully considered the triple points with sufficient operation margins.

6.3 Ventilation system

6.3.1 Spaces that frequently access during the CO₂ unloading are to meet the following requirements:

(1) The electric engine room, CO₂ compressor room and pump room, spaces equipped with CO₂ handling devices and other enclosed spaces where CO₂ may accumulate, are to be provided with fixed mechanical systems that can be controlled outside the aforementioned spaces. A warning notice requiring the use of such ventilation before entering the compartment is to be provided outside these spaces. Failure of the ventilation system^① is to give an audible and visual alarm in the manned spaces during the CO₂ handling operations and the aforementioned compartments requiring ventilation;

(2) The inlets and outlets of mechanical ventilation are to be arranged to ensure sufficient air flow through the areas to avoid the CO₂ accumulation. The ventilation inlets are to be located at the bottom and the outlets are to be located at the top, taking the consideration of the CO₂ density;

(3) The ventilation systems are to provide not less than 30 air changes per hour, and 8 air changes per hour for the CO₂ control room that is not located in the hazardous area;

(4) In the case of failure of any fans for the ventilation system, full ventilation flow rate as required in 6.3.1(3) is still to be provided in each space, or spare parts consisting of electric motor, starting parts and complete rotating components (including various bearings) are to be provided.

6.3.2 Spaces that not frequently access are to meet the following requirements:

(1) Enclosed spaces that may accumulate CO₂ are to be capable of ventilation to ensure a safe environment for entering;

(2) The ventilation systems are to be capable of using before and during entry;

(3) The fixed ventilation systems are to provide 8 air changes per hour and the portable ventilation

^① Ventilation failure alarm can be given by the means of fan operation monitoring or the ventilation flow rate of the space.

systems are to provide 16 air changes per hour. Details of type, quantity, arrangement and accessories of the portable mechanical ventilation fans are to be provided.

6.4 CO₂ unloading

6.4.1 For crew members engaged in CO₂ unloading operations, personnel protection is to meet the requirements of 4.4.2, Section 4, Appendix 4 of PART TWO in the CCS Rules for Liquefied Gases in Bulk.

6.4.2 Where the CO₂ unloading devices are located at the stem or stern of the ship, the ship is to be arranged to meet the requirements of 4.1.4 (8), Section 4, Appendix 4 of PART TWO in the CCS Rules for Liquefied Gases in Bulk. Windows and side scuttles on the end bulkheads of the superstructure or deck room within the aforementioned areas are to be rapid closed and effective airtightness.

6.5 Monitoring and alarm of CO₂ storage tanks

6.5.1 Each CO₂ storage tank is to be provided with a device showing the CO₂ level, pressure and temperature. Pressure gauges and temperature indicators are to be installed in liquid and gas piping systems as well as refrigeration devices.

6.5.2 All remote control devices and indicators related to CO₂ storage tanks are to be centralized at the OCCS control station.

6.5.3 Level measurement

(1) Each CO₂ storage tank is to be fitted with liquid level gauging device, arranged to ensure that a level reading is always obtainable whenever the CO₂ storage tank is operational. The device is to be so designed to operate throughout the design pressure range of the CO₂ storage tank and at temperatures within the CO₂ operating temperature range.

(2) Where only one level gauge is installed, it is to be so arranged to maintain in operation without the need to empty or degass the storage tank. When the storage tank is in operation, any components of the level gauge (excluding passive components) can be maintained and repaired. Passive components are those assumed without failure under normal working conditions;

(3) The liquid level gauge can be an indirect, enclosed or restricted device, as shown in 13.2.3, Chapter 13, of PART THREE in the CCS Rules for Liquefied Gases in Bulk;

(4) The level gauge containing CO₂ installed outside the CO₂ storage tank is to be so arranged to provide isolation in case of failure.

6.5.4 Overflow control

(1) Each CO₂ storage tank is to be fitted with a high liquid level alarm device operating independently of other liquid level indicators and giving an audible and visual warning when activated;

(2) Another sensor operating independently of high liquid level alarm is to automatically actuate a shutoff valve in a manner which will both avoid excessive liquid pressure in the CO₂ supply line and prevent the CO₂ storage tank from becoming liquid full. The closing time of the shutoff valve is to be adjustable;

(3) In one of the following cases, the device specified in aforementioned (1) and (2) may not be required to install in the storage tank:

- ① the storage tank with a volume not more than 200m³; or
- ② the storage tank is designed to withstand the maximum possible pressure during the

loading operation and such pressure is below that of the setting of the storage tank relief valve.

(4) Where an override device is provided for the overflow control system, it is to be capable of preventing improper operations. If conducting overriding, continuous visual indications are to be given at the OCCS control station and bridge room.

6.5.5 Pressure monitoring (included in 6.2.2 of containment system of CO₂ storage tanks)

(1) Each gas space in CO₂ storage tank is to be provided with a direct reading pressure gauge and an indirect indicator at the OCCS control station, which can clearly indicate the maximum and minimum allowable pressures;

(2) A high pressure alarm device is to be provided in bridge room. Where a vacuum protection is required, a low pressure alarm device is also to be provided in bridge room and OCCS control station. Before reaching the setting, an alarm is to be initiated;

(3) Where the storage tank is provided with a pressure relief valve that can adjust more than one pressure, a high pressure alarm is to be set for each pressure;

(4) At least one pressure indicator is to be installed on each CO₂ unloading pipeline;

(5) All pressure indicators are to be capable of providing indications within the operating pressure range.

6.5.6 Temperature indicating device

(1) Each CO₂ storage tank is to be provided with at least two devices for indicating cargo temperatures, one placed at the bottom of the CO₂ storage tank and the another near the top of the tank, below the highest allowable liquid level. The lowest temperature of CO₂ storage tank is to be clearly indicated by means of a sign on or near the temperature indicating devices.

(2) The temperature indicating devices are to be capable of providing temperature indication across the expected CO₂ operating temperature range of the CO₂ storage tanks.

Chapter 7 Control, Monitoring , Alarm and Safety System

7.1 General provisions

7.1.1 In addition to the provisions of this Chapter, the control, monitoring, alarm and safety system of OCCS are to meet the applicable requirements of Chapters 1 and 2 of PART SEVEN in the CCS Rules. Ships assigned with class notation of Automation are to meet the applicable requirements of Section 8, Chapter 3 of PART SEVEN in the CCS Rules.

7.1.2 The computer system used for OCCS control, monitoring, alarm and safety protection is to meet the applicable requirements of Category II computer systems of Section 6, Chapter 2 of PART SEVEN in the CCS Rules.

7.2 Control, monitoring and alarm system

7.2.1 To ensure that the operating parameters of OCCS and its connected engines are always within the specified range, OCCS system is to have automatic control, monitoring, alarm and safety protection functions, and be provided with manual operating devices.

7.2.2 The OCCS control system can be designed as an independent system or integrated into ship automation systems. The system design is to ensure that a single failure of a component does not lead to potential danger for the safety of ships and personnel. When integrating the OCCS control system with the ship automation system, a risk analysis is to be carried out, and the risk analysis report is to be submitted to CCS for information.

7.2.3 For ships with periodic unmanned machinery spaces, the OCCS monitoring and alarm system can be integrated with the centralized monitoring and alarm system of the ship.

7.2.4 The OCCS monitoring, alarm and safety protection is to be determined based on the results of risk analysis. In general, monitoring, alarm and indication can be provided at the OCCS remote control (if equipped) and local control positions according to the requirements of Table 7.2.4. At the meanwhile, all alarms are to be extended to continuously manned positions in the form of single or combined alarms.

7.2.5 In the case of failure of remote control system (if provided) or in emergency, OCCS system is to be locally controlled and monitored. Key parameters required for system safe operation and working conditions of equipment are to be indicated at the local control position.

7.3 Safety system

7.3.1 Emergency shutdown device is to be provided at the OCCS remote control (if equipped) and local control stations to stop system operation and automatically initiate the waste gas bypass device (if equipped). The shutdown of OCCS is not to affect the reliable operation of the engine.

7.3.2 A safety system is to be provided and meet the following requirements:

(1) Upon activation of the safety shutdown system, an audible and visual alarm is to be given at the remote control position and at the local control station. In the event where shutdown by the safety shutdown system is activated the restart is not to occur automatically, until the system has been manually reset.

(2) Safety shutdowns are to be automatically activated according to the requirements of Table 7.2.4.

7.4 Gas detection system

7.4.1 Gas detection system is to be provided in spaces where CO₂ possibly leaks and accumulates during the OCCS operation.

7.4.2 CO₂ gas detection systems and O₂ sensors are to be provided in CO₂ machinery spaces, CO₂ storage tank spaces, enclosed spaces where absorption and desorption towers are installed and other enclosed spaces where CO₂ may accumulate. Where the CO₂ concentration in the spaces exceeds 5000ppm (0.5%) and/or the O₂ concentration is below 19%, an audible and visual alarm is to be given at the following locations:

- (1) OCCS remote control station (if provided);
- (2) OCCS local control station;
- (3) Bridge room;
- (4) Position where gas detector is located.

7.4.3 Gas detection system is to be continuous without delay and of the self-monitoring type. In the event that a system fault is detected by the self-monitoring functions, the output of the detection system is to be automatically disconnected such that the detector fault will not cause false emergency shutdown.

7.4.4 Gas detectors are to be designed and tested according to the standards accepted by CCS.

7.4.5 The number of gas detectors in each space is to be considered taking into account the size, layout and ventilation of the space. Gas detectors are to be located where gas/vapor may accumulate and/or in ventilation outlets. Gas dispersal analysis or physical smoke test is to be used to find the best arrangement.

7.4.6 The gas detection equipment is to be designed so that it may be readily tested.

7.4.7 In addition to the fixed gas detection system, at least two portable gas detectors are to be provided onboard the ship.

Monitoring , Alarm and Safety Protection for OCCS Systems **Table 7.2.4**

Item	Monitored parameter	Display	Alarm	Automatic shutdown or bypass [Ⓞ]	Remark
CO ₂ absorber unit	Inlet pressure of exhaust cooling unit	Pressure	--	--	
	Outlet pressure of exhaust cooling unit	Pressure	--	--	
	Outlet temperature of exhaust cooling unit	Temperature	High	Excessively high	
	Level of absorption tower	Level	High/low	Excessively high/excessively low	
	Pressure of absorption tower	Pressure	High	Excessively high	
	Temperature of absorption tower	Temperature	High	--	

Item	Monitored parameter	Display	Alarm	Automatic shutdown or bypass ^①	Remark
	Outlet pressure of absorbent nozzle	Pressure	Low	--	
	CO ₂ concentration in decarbonized exhaust gas	concentration	High	--	
Decarbonization agent supply system, absorbent circulation system	Outlet pressure of decarbonization agent supply pump*	Pressure	Low	--	
	Condition of decarbonization agent supply pump*	Running	Failed	--	
	Level of decarbonization agent storage tank	Level	High/low	--	
	Lean solution level of absorbent circulation tank	Level	High/low	--	
	Rich solution level of absorbent circulation tank	Level	High/low	--	
	Temperature of absorbent circulation tank	Temperature	--	--	
	Lean solution pH of absorbent circulation tank	pH	--	--	If applicable
	Outlet pressure of absorbent circulation tank (lean solution)	Pressure	low	--	
	OCCS residue tank discharging pipeline pressure	Pressure	--	--	
OCCS residue tank level	Level	High	--		
CO ₂ desorber unit	Outlet pressure of absorbent circulation tank (rich solution)	Pressure	Low	--	
	Rich solution inlet/outlet temperature of lean/rich solution heat exchanger *	Temperature	--	--	
	Lean solution inlet/outlet temperature of lean/rich solution heat exchanger *	Temperature	--	--	
	Lean solution inlet/outlet temperature of Lean solution cooling unit	Temperature	High	--	
	Cooling water inlet/outlet temperature of Lean solution	Temperature	--	--	

Item	Monitored parameter	Display	Alarm	Automatic shutdown or bypass [®]	Remark
	cooling unit				
	Cooling water pump outlet pressure of Lean solution cooling unit	Pressure	Low	--	
	Level of desorption tower	Level	High	--	
	Temperature of desorption tower	Temperature	Low	--	
	Rich solution nozzle outlet pressure of desorption tower	Pressure	High/low	--	
	Heat steam inlet/outlet pressure of reboiler	Pressure	--	--	
	Heat steam inlet/outlet temperature of reboiler	Temperature	--	--	
	Rich solution pump outlet pressure from desorption tower to reboiler	Pressure	Low	--	
	Rich solution inlet pressure from reboiler to desorption tower	Temperature	Low	--	
	Heat Lean solution pump outlet pressure of desorption tower	Pressure	Low	--	
	Cooling water pump outlet pressure of CO ₂ gas	Pressure	Low	--	
	Cooling water inlet/outlet temperature of CO ₂ gas heat exchanger	Temperature	--	--	
CO ₂ compression/liquefaction/storage unit	Cooling water inlet/outlet temperature of compression unit	Temperature	High	--	
	CO ₂ inlet pipeline water content of surge tank*	Moisture	High	--	
	CO ₂ inlet pipeline pressure of surge tank*	Pressure	High	--	
	Surge tank* temperature	Temperature	--	--	
	Surge tank* pressure	Pressure	High	--	
	CO ₂ inlet temperature of liquefaction unit	Temperature	High	--	
	CO ₂ inlet pressure of liquefaction unit	Pressure	High	--	
	Level of CO ₂ storage tank	Level	High	Excessively	

Item	Monitored parameter	Display	Alarm	Automatic shutdown or bybass ^①	Remark
				high	
	Temperature of CO ₂ storage tank	Temperature	High	--	
	Pressure of CO ₂ storage tank	Pressure	High/low	--	If vacuum protection is required, a low pressure alarm is to be provided
	CO ₂ concentration of CO ₂ storage tank spaces (see 7.4.2)	CO ₂ content	High	--	
	O ₂ concentration of CO ₂ storage tank spaces (see 7.4.2)	O ₂ content	low	--	
Miscellaneous	Power source of control, monitoring, alarm and safety system	Voltage	Failed	--	May be replaced by indicating light
	Sensor condition	--	Failed	Failed	Sensors suitable for activating automatic shutdown and bypass functions
	Pump operation	Running	Failed	--	
	Fan required in 6.3.1	Running	Failed	--	
	Pressure of control air pipe	--	Low	--	
	OCCS shutdown	--	Operating	Operating	
	Exhaust gas booster fan*	Running	Failed	--	
	Exhaust gas bybass device*	Working condition	Failed	--	
Exhaust back pressure of combustion unit	--	High	Excessively high		

The symbols and their meanings in the Table are as follows:

--: Not required

*: If provided

^①: Applicable to the bypass device provided according to 2.6.2 of this Guidelines

Chapter 8 Surveys

8.1 General provisions

8.1.1 In addition to the provisions of this Guidelines, the OCCS system is to meet the relevant requirements of applicable rules and standards.

8.1.2 The OCCS survey categories are to include product survey, survey during construction and survey after construction.

8.2 Drawings examination

8.2.1 Before the commencement of construction, the applicant is to submit triplicated or electronic drawings and information specified in 1.5 of Chapter 1 in this Guidelines to CCS for approval.

8.2.2 Technical documents, system commissioning and functional and effectiveness testing programs are to be submitted to the CCS field surveyors for approval.

8.3 Product surveys

8.3.1 The product survey and approval of OCCS are to meet the applicable requirements of CCS rules and product inspection guidelines.

8.3.2 Equipment, piping and valves related to OCCS are to be approved by CCS with relevant certification documents before installation on board the ships.

8.3.3 The welding, heat treatment and non-destructive testing of pressure vessels are to be carried out in accordance with the relevant documents approved by CCS.

8.4 Surveys during construction

8.4.1 Before the construction of OCCS, the applicant is to submit a written application for construction surveys to CCS or sign a survey contract.

8.4.2 Design review and survey are to be carried out for the manufacturer's self-made equipment in accordance with the requirements of product surveys in 8.3 of this Guidelines. When the equipment is assembled, the CCS field surveyors are to inspect the equipment assembly, pipelines, and electrical installations according to the approved drawings and test procedures, and witness the pressure and functional tests of the relevant equipment or pipelines.

8.4.3 Before the commencement of construction, CCS field surveyors are to inspect and confirm the relevant construction and inspection preparations made by the manufactures, e.g.: construction preparation work plan, construction/welding processes, welder/non-destructive testing personnel qualifications, list of marine product certificates, welding specifications, non-destructive testing plan, tightness test plan, inspection/test items, relevant materials (steel plating, welding materials, etc.), construction tolerance standards, subcontractors (if applicable) and necessary technical information, i.e. drawings and data before commencement of construction. For individual projects that do not affect the commencement of construction, CCS field surveyors may carry out inspection and confirmation case by case before the relevant construction stage.

8.4.4 CCS field surveyors are to approve the construction processes and test programs to confirm that they are in compliance with the approved drawings and data (including plan approval comments) and relevant rules, and carry out surveys according to the approved drawings, data,

processes and test programs.

8.4.5 The as-built documents are to include installation reports, test reports and equipment delivery certificates.

8.4.6 The installation of the system and equipment are to be checked whether it is in compliance with the drawings so as to verify the performance and operation meet the design requirements.

(1) Pumps

- ① Visual inspection;
- ② The safety device alarm and shutdown functional test is satisfactory;
- ③ Starting and shutdown test;
- ④ Check the parameters of pumps.

(2) Compressors

- ① Visual inspection;
- ② Testing the alarm and shutdown protection by means of simulation;
- ③ Starting and shutdown test;
- ④ During the operation test, checking the automatic unloading and loading functions of the compressor, and test the parameters of the compressors, motors and associated equipment.

(3) Heat exchangers

- ① Visual inspection;
- ② Inlet and outlet pressure and temperature of heat exchanges are in compliance with the design requirements;
- ③ The safety device alarm and shutdown functional test is satisfactory;

(4) Pressure vessels

- ① Visual inspection and internal inspection;
- ② The following alarm and shutdown protection is carried out by means of simulation, generally including:
 - a. High or low pressure alarm and shutdown protection;
 - b. High or low level alarm and shutdown protection;
 - c. Low temperature alarm and protection.

(5) Gas detection system

- ① Confirm the installation of gas detection system meeting the relevant requirements of 7.4 in this Guidelines;
- ② Confirm that the gas detectors have been calibrated by the qualified firms;
- ③ Confirm that the gas detection system has been commissioned and meet the requirements.

(6) CO₂ piping system

- ① Visual inspection;
- ② Check for leaks and looseness at the connections of flanges, valves, and accessories;
- ③ Hydraulic test;
- ④ Safety alarm and shutdown functional test are satisfactory.

8.4.7 Visual inspection is to be carried out for OCCS arrangements required in Chapter 2 of this Guidelines.

8.5 Surveys after construction

8.5.1 Annual survey is to be carried out for OCCS system. The survey items are the same as the requirements of 8.4.6 and 8.4.7 in this Guidelines, except for the internal inspection of pressure

vessels and hydraulic testing of CO₂ piping systems.

8.5.2 Intermediate survey is to be carried out for OCCS system, with the survey items as the same as the annual survey.

8.5.3 Special survey is to be carried out for OCCS system, with the survey items as the same as the requirements of 8.4.6 and 8.4.7 in this Guidelines.

8.5.4 Where an OCCS is modified, renewed, damaged or repaired that may affect system safety, or where the system delivery condition changes, an application for occasional survey is to be submitted to CCS in a timely manner.

Chapter 9 Ready Technology Requirements for OCCS

9.1 General provisions

9.1.1 This Chapter applies to OCCS Ready ships which intend for OCCS installation and modification in future. Such ships are also to meet the requirements of competent authorities (if any).

9.1.2 This Chapter provides the requirements of design, arrangement, space reservation, structural strengthening and surveys for the OCCS Ready ships.

9.1.3 This Chapter intends to clarify the OCCS Ready requirements and provides technical guidance for the subsequent installation and modification of OCCS onboard the ships.

9.2 Requirements of ready

9.2.1 The OCCS Ready is to meet the following functional requirements:

- (1) The layout and design of OCCS Ready are to reduce the probability and consequences of risks related to OCCS to a minimum level;
- (2) In the event of failure of OCCS, necessary safety measures are to be initiated, taking the consideration that these safety measures will not cause unacceptable power loss to the ship;
- (3) The OCCS Ready is to be arranged by taking the consideration to reduce the hazardous areas as much as possible to minimize the potential risks that may affect the safety of ships, personnel, and equipment on board the ships.

9.2.2 Ships applying for the class notation OCCS Ready 1 are to comprehensively consider the space required for installation and maintenance, as well as the potential impact on ship layout, equipment, electrical load, structural strength, stability, tonnage, and load capacity.

9.2.3 Ships applying for the class notation OCCS Ready 2 are to meet the relevant requirements of class notation OCCS in this Guidelines, in addition to the requirements of 9.2.2 of this Guidelines.

9.2.4 Ships applying for the class notation OCCS Ready 2 (X) are to meet the relevant survey requirements related to the suffix "X", in addition to the requirements of 9.2.2 and 9.2.3 of this Guidelines.

9.3 Plans and information

9.3.1 In addition to submit the drawings and information in accordance with the relevant requirements of CCS rules and guidelines, ships applying for the class notation OCCS Ready 1 are also to provide:

- (1) The followings are to be submitted for approval, as a minimum:
 - ① General arrangement, including the reserved layout of OCCS;
 - ② Power load calculation sheet.
- (2) The followings are to be submitted for information, as a minimum:
 - ① OCCS Ready and layout instructions;
 - ② OCCS steam consumption calculation sheet (if applicable);
 - ③ Longitudinal strength calculation sheet (taking into account the impacts of OCCS on ship weight distribution)

9.3.2 Ships applying for class notations OCCS Ready 2 or OCCS Ready 2 (X) are to submit the drawings and information in accordance to the requirements of 1.5 in this Guidelines.

9.4 Surveys

9.4.1 Ships applying for class notation OCCS Ready 2 (X) are to surveyed in accordance with the applicable requirements of Chapter 8 in this Guidelines.

9.4.2 The equipment related to OCCS installed at the Ready stage is to be surveyed in accordance with the relevant requirements of the Onboard Carbon Capture and Storage System (No. K-08) in CCS Guidelines for Product Surveys.